



KENNEDY VALVE

Division of McWane, Inc.

1021 East Water Street

P.O. Box 931

Elmira, New York 14902-0931

Telephone (607) 734-2211

Fax (607) 734-1003

Certificate of Compliance

[Vertical and Wall Style Indicator Posts]

This is to certify that the Figure 2945(A)(ALV) Vertical Indicator Posts and 2945W Wall Posts are manufactured by Kennedy Valve located in Elmira, New York, USA facility meet or exceed all dimensional, material and test specifications of Underwriters Laboratories (UL-789) and Factory Mutual (FM-1110) Standards for Safety.

The Figure 2945(A)(ALV) Vertical Indicator Posts and 2945W Wall Posts comes standard with a machined port to accept a limit switch when used on open left valves.

The above grade surfaces are coated with “Ken-Guard” thermosetting TGIC Polyester, which is a highly cross linked, outdoor durable powder coating, characterized by excellent color and gloss retention and UV resistance. Below grade ductile iron standpipe is coated with asphaltic emulsion. The indicator post base casting is coated with “Ken-Guard” TGIC Polyester.

The Kennedy 2945(A)(ALV) Vertical Indicator Posts and 2945W Wall Posts are intended to be used on valves which have been installed per NFPA 24 (Standard for the Installing of Private Fire Service Mains and Their Appurtenances) and any local, state or country codes.

June 27, 2024

Daniel Burczynski

Kennedy Valve Engineering Manager

ISO 9001:2015 Certified

ISO 14001:2015 Certified