

## KENNEDY VALVE

Division of McWane, Inc.

1021 East Water Street P.O. Box 931 Elmira, New York 14902-0931 Telephone (607) 734-2211 Fax (607) 734-1003

## **Certificate of Compliance**

[ Rotating Disc Gate Valves ]

This is to certify that the Rotating Disc Metal Seated Gate Valves supplied by Kennedy Valve shall meet or exceeds all dimensional, material, and test specifications, per the latest edition ANSI/AWWA C-500 (Metal-Seated Gate Valves for Water Supply Service). \*\* Valves sizes that fall outside the scope of the current AWWA standard will be manufactured and tested as closely as possible to the current standard.

Each valve undergoes operational tests to ensure free and proper functioning of parts in the intended manner and are operated through a complete cycle and in the orientation that the valve will be installed and using the supplied actuation.

- \* All valves are Hydrostatically Tested at a minimum of twice the rated working pressure, for a duration that is adequate to determine that no leaks exist through the metal, flanged joints or stem seals. Seat testing is performed bidirectionally at the rated working pressure. Leakage by either seat shall not exceed a rate of 1 oz/hr/in. of nominal valve size.
- \* The interior and exterior surfaces of all Rotating Disc Gate Valves are epoxy coated with a material that meets/exceeds the coating requirements prescribed in ANSI/AWWA C500 and ANSI/AWWA C550 (Protective Interior Coatings for Valves and Hydrants) and certified by National Sanitation Foundation (NSF) and meet ANSI/NSF Standard 61 (Drinking Water System Components Health Effects) and ANSI/NSF 372 (Drinking Water System Components Lead Content).

If required by the customer order coating shall be Holiday Free per ASTM D5162.

\* *Unless otherwise specified in the purchase documents.* 

June 27, 2024

Daniel Burczynski Kennedy Valve Engineering Manager